

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7315-0061:108 Page 1 of 1

CATEGORY: Power Units

LISTEE: Chemetron Fire Systems, 4801 Southwick Drive, 3rd Floor, Matteson, IL 60443
Contact: Gary Kimble (708) 283-4447 FAX (708) 283-6500

DESIGN: Model 70101114 power supply/battery charger. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 120/240 VAC Primary, 24 VDC Secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a power supply/battery charger for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

XLF: 7315-1076:165

05-28-03KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 18, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager